

December 1, 2020

Mr. Eric Miller
Maintenance Supervisor
Wellsville Central School District
126 West State Street
Wellsville, NY 14895

RE: Investigation and Sampling of Drinking Water for Lead Concentrations

Dear Mr. Miller:

Included with this letter is Stohl Environmental LLC's report for the Water Sampling performed at the educational buildings of the Wellsville Central School District, including:

- Wellsville Secondary School – 126 West State Street, Wellsville, New York.

This report is prepared to assist the District in complying with the requirements of NYS regulations, *SUBPART 67-4: Lead Testing in School Drinking Water*, by identifying the sources of potable water with lead concentrations greater than the NYS "Action Level of 15 parts per billion (ppb)".

The Investigation and Sampling was performed on October 14, 2020. The Protocol for the Investigation followed the requirements of NYS regulations as well as USEPA Technical Guidance Document "3-T's for Reducing Lead in Drinking Water in Schools".

As detailed in Section 1.2 (*Executive Summary*) of the accompanying report, based upon the sampling and analysis performed, 9 sources of potable water in the Secondary School have been identified as having lead concentrations in water above the NYS Action Level of 15 parts per billion. To comply with NYS regulations, Response actions as identified in this report by the District are required.

Thank you for the opportunity to be of service to Wellsville Central School District.

Sincerely,
Stohl Environmental, LLC.



Eric Henderson Jr.
Senior Project Manager

**Investigation and Sampling
Of Sources of Potable Water
For Lead Concentrations**

Prepared for:

Wellsville Central School District

Prepared by:



**3860 California Road, Orchard Park, New York 14127
PHONE (716) 312-0070 FAX (716) 312-8092
WWW.STOHLENVIRONMENTAL.COM**

Conditions as of October 14, 2020

Summary Tabulation

Lead in Drinking Water Investigation

- 1.1. Scope of Work and Sampling Protocol
- 1.2. Executive Summary of Sampling and Analysis
- 1.3. Response Actions Required Under NYS Regulations
- 1.4. Laboratory Analytical Reports by Building
- 1.5. Laboratory Certifications
- 1.6. Chains of Custody

1.1 Scope of Work and Sampling Protocol:

Stohl Environmental was retained by Wellsville Central School District to perform sampling and analysis of potable water for elevated lead concentrations. Sampling was performed in the following buildings:

- Wellsville Secondary School – 126 West State Street, Wellsville, New York.

Scope of Work:

Stohl Environmental was charged with collecting first-draw water samples from outlets within the Secondary School. Outlets are defined in NYS regulations as: “a potable water fixture currently or potentially used for drinking or cooking purposes, including but not limited to a bubbler, drinking fountain, or faucets”.

Sampling Protocol:

In accordance with NYS regulations, ***Subpart 67-4: Lead Testing in School Drinking Water***, and the EPA guidance document, ***‘3Ts for Reducing Lead in Drinking Water in Schools’***, Stohl Environmental’s protocol can be summarized as follows:

- **First-draw samples** of 250 milliliters (mL) were collected from cold water outlets before any water was used. Sampling was coordinated with District representatives to assure that water was motionless in the pipes for a minimum of 8 hours, but not more than 18 hours before sample collection.
- **Laboratory Analysis:** Samples were submitted following strict chain-of-custody protocols to an independent laboratory approved by the NYS Department of Health’s Environmental Laboratory Approval Program (ELAP).

1.2 Executive Summary of Sampling and Analysis:

Total Number of Samples Collected by Building Classified by First Draw & Confirmatory Samples:

Building Name	Date of Sample Event	Total Number Samples Collected	First Draw Samples		Confirmatory Samples **	
			Number of Samples at or Below Action level of 15 ppb	Number of Samples Above Action Level of 15 ppb	Number of Samples at or Below Action level of 15 ppb	Number of Samples Above Action Level of 15 ppb
Secondary School	10/14/2020	135	126	9	N/A	N/A

** Confirmatory samples are samples collected subsequent to "Step 1" First Draw samples to verify initial findings of lead contamination, to assist in problem assessment to determine remediation and/or verify that lead levels are at or below action level post-remediation.

Listing of Outlets Requiring Remediation

Locations of Outlets Analyzed above the NYS Action Level of 15 parts per billion based upon Analysis of First Draw Samples:

Sample #	Classroom or other Location	Fixture/Outlet type	Laboratory Analysis in ppb
115-.1-15A	Boy's HS Locker Room Left	Sink	15.8
115-.1-15B	Boy's HS Locker Room Middle	Sink	33.2
115-.1-30B	Girl's Locker Room Right	Sink	22.6
115-.1-33G	Kitchen Triple Right	Sink	39.0
115-.1-52	Fitness Area Boy's Bathroom	Sink	19.8
115-.1-53	Fitness Area Girl's Bathroom	Sink	16.2
115-.1-58B	Room 106	Sink	46.0
115-.1-58C	Room 106	Sink	1460
115-.1-62	Chem. Room	Sink	43.6

1.3 Response Actions Required Under NYS Regulations, Section 67-4.4:

For outlets analyzed with a lead concentration in excess of the NYS Action Level, regulations require:

- (a) Prohibit use of the outlet until:
 - (1) a lead remediation plan is implemented to mitigate the lead level of such outlet; and
 - (2) test results indicate that the lead levels are at or below the action level;
- (b) provide building occupants with an adequate supply of potable water for drinking and cooking until remediation is performed;
- (c) report the test results to the local health department as soon as practicable, but no more than 1 business day after the school received the laboratory report; and
- (d) notify all staff and all persons in parental relation to students of the test results, in writing, as soon as practicable but no more than 10 business days after the school received the laboratory report.

1.4 Laboratory Analytical Reports by Building

CERTIFICATE OF ANALYSIS

Client: Stohl Environmental
3860 California Road
Orchard Park NY 14127

Client: STO708

Report Date: 10/22/2020
Report No.: 621510 - Lead Water
Project: Wellsville CSD; Wellsville Secondary School
Project No.: 2020L-115.1

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.: 7081067 Location: Drinking Fountain 3 Floor MS DF Result(ppb): <1.00
Client No.: 115.1-1A * Sample acidified to pH <2.

Lab No.: 7081068 Location: Bottle Filler 3 Floor MS DFB Result(ppb): <1.00
Client No.: 115.1-1B * Sample acidified to pH <2.

Lab No.: 7081069 Location: Faculty Across 306 3 Floor MS L S Result(ppb): <1.00
Client No.: 115.1-2 * Sample acidified to pH <2.

Lab No.: 7081070 Location: Boys Bathroom 3 Floor MS L S Result(ppb): 1.30
Client No.: 115.1-3A * Sample acidified to pH <2.

Lab No.: 7081071 Location: Girls Bathroom 3 Floor MS L S Result(ppb): 3.30
Client No.: 115.1-4A * Sample acidified to pH <2.

Lab No.: 7081072 Location: Girls Bathroom 3 Floor MS M S Result(ppb): 1.90
Client No.: 115.1-4B * Sample acidified to pH <2.


Lab No.: 7081073 Location: Girls Bathroom 3 Floor MS R S Result(ppb): 4.30
Client No.: 115.1-4C * Sample acidified to pH <2.


Lab No.: 7081074 Location: Faculty By Elevator 3 Floor MS S Result(ppb): <1.00
Client No.: 115.1-5 * Sample acidified to pH <2.

Lab No.: 7081075 Location: Drinking Fountain 3 Floor HS DF Result(ppb): <1.00
Client No.: 115.1-6A * Sample acidified to pH <2.

Lab No.: 7081076 Location: Bottle Filler 3 Floor HS DFB Result(ppb): <1.00
Client No.: 115.1-6B * Sample acidified to pH <2.

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 10/19/2020
Date Analyzed: 10/21/2020
Signature: 
Analyst: Chad Shaffer

Approved By: 
Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: Stohl Environmental
3860 California Road
Orchard Park NY 14127

Client: STO708

Report Date: 10/22/2020
Report No.: 621510 - Lead Water
Project: Wellsville CSD; Wellsville Secondary School
Project No.: 2020L-115.1

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.: 7081077 **Location:** Boys Bathroom 3 Floor HS L S **Result(ppb):** 3.80
Client No.: 115.1-7A * Sample acidified to pH <2.

Lab No.: 7081078 **Location:** Boys Bathroom 3 Floor HS M S **Result(ppb):** 1.50
Client No.: 115.1-7B * Sample acidified to pH <2.

Lab No.: 7081079 **Location:** Boys Bathroom 3 Floor HS R S **Result(ppb):** 2.50
Client No.: 115.1-7C * Sample acidified to pH <2.

Lab No.: 7081080 **Location:** Girls Bathroom 3 Floor HS L S **Result(ppb):** 3.00
Client No.: 115.1-8A * Sample acidified to pH <2.

Lab No.: 7081081 **Location:** Girls Bathroom 3 Floor HS M S **Result(ppb):** 1.50
Client No.: 115.1-8B * Sample acidified to pH <2.

Lab No.: 7081082 **Location:** Girls Bathroom 3 Floor HS R S **Result(ppb):** 2.70
Client No.: 115.1-8C * Sample acidified to pH <2.


Lab No.: 7081083 **Location:** Faculty Bathroom 3 Floor HS S **Result(ppb):** <1.00
Client No.: 115.1-9 * Sample acidified to pH <2.


Lab No.: 7081084 **Location:** Drinking Fountain 2nd HS DF **Result(ppb):** <1.00
Client No.: 115.1-10A * Sample acidified to pH <2.

Lab No.: 7081085 **Location:** Bottle Filler 2nd HS DFB **Result(ppb):** <1.00
Client No.: 115.1-10B * Sample acidified to pH <2.

Lab No.: 7081086 **Location:** Boys Bathroom 2nd HS I S **Result(ppb):** 2.40
Client No.: 115.1-11A * Sample acidified to pH <2.

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 10/19/2020
Date Analyzed: 10/21/2020
Signature: 
Analyst: Chad Shaffer

Approved By: 
Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: Stohl Environmental
3860 California Road
Orchard Park NY 14127


Client: STO708


Report Date: 10/22/2020
Report No.: 621510 - Lead Water
Project: Wellsville CSD; Wellsville Secondary School
Project No.: 2020L-115.1

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.: 7081087 Client No.: 115.1-11B	Location: Boys Bathroom 2nd HS m S * Sample acidified to pH <2.	Result(ppb): 2.10
Lab No.: 7081088 Client No.: 115.1-12A	Location: Girls bathroom 2nd hs l S * Sample acidified to pH <2.	Result(ppb): 2.60
Lab No.: 7081089 Client No.: 115.1-12B	Location: Girls bathroom 2nd hsm S * Sample acidified to pH <2.	Result(ppb): 1.70
Lab No.: 7081090 Client No.: 115.1-13A	Location: Drink fountain 2nd hs 210 DF * Sample acidified to pH <2.	Result(ppb): <1.00
Lab No.: 7081091 Client No.: 115.1-13B	Location: Bottle Fill 2nd hs 210 DFB * Sample acidified to pH <2.	Result(ppb): <1.00
Lab No.: 7081092 Client No.: 115.1-14	Location: Faculty Bathroom 2nd ms S * Sample acidified to pH <2.	Result(ppb): <1.00
Lab No.: 7081093 Client No.: 115.1-15A	Location: Boys hs Locker Room L S * Sample acidified to pH <2.	Result(ppb): 15.8

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 10/19/2020
Date Analyzed: 10/21/2020
Signature: 
Analyst: Chad Shaffer

Approved By: 
Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: Stohl Environmental
3860 California Road
Orchard Park NY 14127

Client: STO708

Report Date: 10/22/2020
Report No.: 621510 - Lead Water
Project: Wellsville CSD; Wellsville Secondary School
Project No.: 2020L-115.1

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.: 7081094

Client No.: 115.1-15B

Location: Boys hs Locker Room M S

* Sample acidified to pH <2.

Result(ppb): 33.2

Note: Sample turbidity >1.0 NTU. Does not meet Federal and NJ State Primary and Secondary Drinking Water Standards.

Please refer to the Appendix of this report for further information regarding your analysis.


Date Received: 10/19/2020

Date Analyzed: 10/22/2020

Signature:

Analyst: Chad Shaffer

Approved By:



Frank E. Ehrenfeld, III

Laboratory Director

CERTIFICATE OF ANALYSIS

Client: Stohl Environmental
3860 California Road
Orchard Park NY 14127


Client: STO708


Report Date: 10/22/2020
Report No.: 621510 - Lead Water
Project: Wellsville CSD; Wellsville Secondary School
Project No.: 2020L-115.1

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.: 7081095 Client No.: 115.1-16	Location: Boys hs Gym Office S * Sample acidified to pH <2.	Result(ppb): 1.20
Lab No.: 7081096 Client No.: 115.1-17A	Location: Hs Gym Drinking Fountain DF * Sample acidified to pH <2.	Result(ppb): <1.00
Lab No.: 7081097 Client No.: 115.1-17B	Location: Hs Gym Bottle Fill DFB * Sample acidified to pH <2.	Result(ppb): <1.00
Lab No.: 7081098 Client No.: 115.1-18	Location: Girls hs Gym Office S * Sample acidified to pH <2.	Result(ppb): 1.20
Lab No.: 7081099 Client No.: 115.1-19A	Location: Girls hs Locker Room L S * Sample acidified to pH <2.	Result(ppb): 7.00
Lab No.: 7081100 Client No.: 115.1-19B	Location: Girls hs Locker Room M S * Sample acidified to pH <2.	Result(ppb): 4.90
Lab No.: 7081101 Client No.: 115.1-19C	Location: Girls hs Locker Room R S * Sample acidified to pH <2.	Result(ppb): 9.10
Lab No.: 7081102 Client No.: 115.1-20	Location: Faculty Room 2nd ms S * Sample acidified to pH <2.	Result(ppb): <1.00
Lab No.: 7081103 Client No.: 115.1-21	Location: Faculty Bathroom 2nd ms S * Sample acidified to pH <2.	Result(ppb): <1.00
Lab No.: 7081104 Client No.: 115.1-22A	Location: Girls Bathroom 2nd ms L S * Sample acidified to pH <2.	Result(ppb): 2.90

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 10/19/2020
Date Analyzed: 10/21/2020
Signature: 
Analyst: Chad Shaffer

Approved By: 
Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: Stohl Environmental
3860 California Road
Orchard Park NY 14127

Report Date: 10/22/2020
Report No.: 621510 - Lead Water
Project: Wellsville CSD; Wellsville Secondary School
Project No.: 2020L-115.1

Client: STO708

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.: 7081105
Client No.: 115.1-22B

Location: Girls Bathroom 2nd ms M S
* Sample acidified to pH <2.

Result(ppb): 1.20

Lab No.: 7081106
Client No.: 115.1-22C

Location: Girls Bathroom 2nd ms R S
* Sample acidified to pH <2.

Result(ppb): 1.70

Lab No.: 7081107
Client No.: 115.1-23A

Location: Boys Bathroom 2nd ms L S
* Sample acidified to pH <2.

Result(ppb): 1.40

Lab No.: 7081108
Client No.: 115.1-23B

Location: Boys Bathroom 2nd ms M S
* Sample acidified to pH <2.

Result(ppb): 1.60

Please refer to the Appendix of this report for further information regarding your analysis.


Date Received: 10/19/2020

Date Analyzed: 10/21/2020

Signature:

Analyst: Chad Shaffer

Approved By:



Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: Stohl Environmental
3860 California Road
Orchard Park NY 14127

Client: STO708

Report Date: 10/22/2020
Report No.: 621510 - Lead Water
Project: Wellsville CSD; Wellsville Secondary School
Project No.: 2020L-115.1

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.: 7081109 **Location:** 2nd ms Water Fountain DF **Result(ppb):** <1.00
Client No.: 115.1-24A * Sample acidified to pH <2.

Lab No.: 7081110 **Location:** 2nd ms Bottle Fill DFB **Result(ppb):** <1.00
Client No.: 115.1-24B * Sample acidified to pH <2.

Lab No.: 7081111 **Location:** 2nd Floor Shorter Fountain DF **Result(ppb):** <1.00
Client No.: 115.1-24C * Sample acidified to pH <2.

Lab No.: 7081112 **Location:** Faculty Room By Water Ftn S **Result(ppb):** 1.20
Client No.: 115.1-25 * Sample acidified to pH <2.

Lab No.: 7081113 **Location:** Drinking Fountain Across From Kitchen S **Result(ppb):** <1.00
Client No.: 115.1-26A * Sample acidified to pH <2.

Lab No.: 7081114 **Location:** Bottle Fill Across From Kitchen S **Result(ppb):** <1.00
Client No.: 115.1-26B * Sample acidified to pH <2.


Lab No.: 7081115 **Location:** Staff Locker Room S **Result(ppb):** <1.00
Client No.: 115.1-27 * Sample acidified to pH <2.


Lab No.: 7081116 **Location:** Girls Bathroom Across Kitchen L S **Result(ppb):** 1.10
Client No.: 115.1-28A * Sample acidified to pH <2.

Lab No.: 7081117 **Location:** Girls Bathroom Across Kitchen M S **Result(ppb):** <1.00
Client No.: 115.1-28B * Sample acidified to pH <2.

Lab No.: 7081118 **Location:** Girls Bathroom Across Kitchen R S **Result(ppb):** 1.00
Client No.: 115.1-28C * Sample acidified to pH <2.

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 10/19/2020
Date Analyzed: 10/22/2020
Signature: 
Analyst: Chad Shaffer

Approved By: 
Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: Stohl Environmental
3860 California Road
Orchard Park NY 14127


Client: STO708


Report Date: 10/22/2020
Report No.: 621510 - Lead Water
Project: Wellsville CSD; Wellsville Secondary School
Project No.: 2020L-115.1

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.: 7081119 Client No.: 115.1-29A	Location: Boys Bathroom Across Kitchen L S * Sample acidified to pH <2.	Result(ppb): 1.10
Lab No.: 7081120 Client No.: 115.1-29B	Location: Boys Bathroom Across Kitchen M S * Sample acidified to pH <2.	Result(ppb): <1.00
Lab No.: 7081121 Client No.: 115.1-29C	Location: Boys Bathroom Across Kitchen R S * Sample acidified to pH <2.	Result(ppb): <1.00
Lab No.: 7081122 Client No.: 115.1-30A	Location: Girls Locker Room Sink L S * Sample acidified to pH <2.	Result(ppb): 5.80
Lab No.: 7081123 Client No.: 115.1-30B	Location: Girls Locker Room Sink R S * Sample acidified to pH <2.	Result(ppb): 22.6
Note: Sample turbidity >1.0 NTU. Does not meet Federal and NJ State Primary and Secondary Drinking Water Standards.		
Lab No.: 7081124 Client No.: 115.1-30C	Location: Girls Locker Room ms Drinking DF * Sample acidified to pH <2.	Result(ppb): 3.90
Lab No.: 7081125 Client No.: 115.1-31B	Location: Boys ms Locker Room Sink L S * Sample acidified to pH <2.	Result(ppb): 6.60
Lab No.: 7081126 Client No.: 115.1-31C	Location: Boys ms Locker Room Drinking Ftn DF * Sample acidified to pH <2.	Result(ppb): 4.30
Lab No.: 7081127 Client No.: 115.1-32	Location: Boys PE Office ms S * Sample acidified to pH <2.	Result(ppb): <1.00
Lab No.: 7081128 Client No.: 115.1-33A	Location: Kitchen Ice Machine IM * Sample acidified to pH <2.	Result(ppb): <1.00

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 10/19/2020
Date Analyzed: 10/22/2020
Signature: 
Analyst: Chad Shaffer

Approved By: 
Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: Stohl Environmental
3860 California Road
Orchard Park NY 14127

Client: STO708

Report Date: 10/22/2020
Report No.: 621510 - Lead Water
Project: Wellsville CSD; Wellsville Secondary School
Project No.: 2020L-115.1

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.: 7081129 **Location:** Kitchen Dish Hose S **Result(ppb):** 2.30
Client No.: 115.1-33B * Sample acidified to pH <2.

Lab No.: 7081130 **Location:** Kitchen Dish Room Hand Wash Front S **Result(ppb):** 4.10
Client No.: 115.1-33C * Sample acidified to pH <2.

Lab No.: 7081131 **Location:** Kitchen Ice Room Hand Wash Front S **Result(ppb):** <1.00
Client No.: 115.1-33D * Sample acidified to pH <2.

Lab No.: 7081132 **Location:** Kitchen Main S **Result(ppb):** 1.20
Client No.: 115.1-33E * Sample acidified to pH <2.

Lab No.: 7081133 **Location:** Kitchen Triple L S **Result(ppb):** <1.00
Client No.: 115.1-33F * Sample acidified to pH <2.

Lab No.: 7081134 **Location:** Kitchen Triple R S **Result(ppb):** 39.0
Client No.: 115.1-33G * Sample acidified to pH <2.
Note: Sample turbidity >1.0 NTU. Does not meet Federal and NJ State Primary and Secondary Drinking Water Standards.


Lab No.: 7081135 **Location:** Kitchen Hand Wash Next To Triple S **Result(ppb):** 1.00
Client No.: 115.1-33H * Sample acidified to pH <2.


Lab No.: 7081136 **Location:** Kitchen Kettle Rice Cooker S **Result(ppb):** 2.70
Client No.: 115.1-33I * Sample acidified to pH <2.

Lab No.: 7081137 **Location:** Kitchen Back Dish Room Sink Hose S **Result(ppb):** 1.40
Client No.: 115.1-33J * Sample acidified to pH <2.

Lab No.: 7081138 **Location:** Kitchen Back Dish Room Hand Wash S **Result(ppb):** <1.00
Client No.: 115.1-33K * Sample acidified to pH <2.

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 10/19/2020
Date Analyzed: 10/22/2020
Signature: 
Analyst: Chad Shaffer

Approved By: 
Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: Stohl Environmental
3860 California Road
Orchard Park NY 14127


Client: STO708


Report Date: 10/22/2020
Report No.: 621510 - Lead Water
Project: Wellsville CSD; Wellsville Secondary School
Project No.: 2020L-115.1

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.: 7081139 Client No.: 115.1-33L	Location: Kitchen Wall Mount Faucet S * Sample acidified to pH <2.	Result(ppb): 12.9
Lab No.: 7081140 Client No.: 115.1-33M	Location: Kitchen Double Sink S * Sample acidified to pH <2.	Result(ppb): 6.00
Lab No.: 7081141 Client No.: 115.1-34A	Location: Cafe Drinking Fountain Right DF * Sample acidified to pH <2.	Result(ppb): <1.00
Lab No.: 7081142 Client No.: 115.1-34B	Location: Cafe Bottle Fill Right DFB * Sample acidified to pH <2.	Result(ppb): <1.00
Lab No.: 7081143 Client No.: 115.1-35A	Location: Cafe Drinking Fountain Left DF * Sample acidified to pH <2.	Result(ppb): <1.00
Lab No.: 7081144 Client No.: 115.1-35B	Location: Cafe Bottle Fill Left DFB * Sample acidified to pH <2.	Result(ppb): <1.00
Lab No.: 7081145 Client No.: 115.1-36B	Location: Girls Bathroom ms 1st M S * Sample acidified to pH <2.	Result(ppb): <1.00
Lab No.: 7081146 Client No.: 115.1-37A	Location: Boys Bathroom ms 1st L S * Sample acidified to pH <2.	Result(ppb): 3.50
Lab No.: 7081147 Client No.: 115.1-37B	Location: Boys Bathroom ms 1st M S * Sample acidified to pH <2.	Result(ppb): <1.00
Lab No.: 7081148 Client No.: 115.1-37C	Location: Boys Bathroom ms 1st R S * Sample acidified to pH <2.	Result(ppb): 1.50

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 10/19/2020
Date Analyzed: 10/22/2020
Signature: 
Analyst: Chad Shaffer

Approved By: 
Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: Stohl Environmental
3860 California Road
Orchard Park NY 14127

Client: STO708

Report Date: 10/22/2020
Report No.: 621510 - Lead Water
Project: Wellsville CSD; Wellsville Secondary School
Project No.: 2020L-115.1

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.: 7081149 Location: Ms 1st Faculty Bathroom S Result(ppb): <1.00
Client No.: 115.1-38 * Sample acidified to pH <2.

Lab No.: 7081150 Location: Ms 1st Drinking Ftn Next To Faculty S Result(ppb): <1.00
Client No.: 115.1-39A * Sample acidified to pH <2.

Lab No.: 7081151 Location: Ms 1st Bottle Fill Next To Faculty S Result(ppb): <1.00
Client No.: 115.1-39B * Sample acidified to pH <2.

Lab No.: 7081152 Location: Art Room 142 Clockwise Around Room S Result(ppb): 1.40
Client No.: 115.1-40A * Sample acidified to pH <2.

Lab No.: 7081153 Location: Art Room 142 S Result(ppb): 2.20
Client No.: 115.1-40B * Sample acidified to pH <2.

Lab No.: 7081154 Location: Art Room 142 S Result(ppb): <1.00
Client No.: 115.1-40C * Sample acidified to pH <2.


Lab No.: 7081155 Location: Art Room 142 S Result(ppb): <1.00
Client No.: 115.1-40D * Sample acidified to pH <2.


Lab No.: 7081156 Location: Art Room 142 S Result(ppb): 1.20
Client No.: 115.1-40E * Sample acidified to pH <2.

Lab No.: 7081157 Location: Art Room 142 S Result(ppb): 2.50
Client No.: 115.1-40F * Sample acidified to pH <2.

Lab No.: 7081158 Location: Art Room 139 Far Left S Result(ppb): 1.10
Client No.: 115.1-41A * Sample acidified to pH <2.

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 10/19/2020
Date Analyzed: 10/22/2020
Signature: 
Analyst: Chad Shaffer

Approved By: 
Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: Stohl Environmental
3860 California Road
Orchard Park NY 14127


Client: STO708


Report Date: 10/22/2020
Report No.: 621510 - Lead Water
Project: Wellsville CSD; Wellsville Secondary School
Project No.: 2020L-115.1

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.: 7081159 Client No.: 115.1-41B	Location: Art Room 139 Middle Left S * Sample acidified to pH <2.	Result(ppb): 2.20
Lab No.: 7081160 Client No.: 115.1-41C	Location: Art Room 139 Middle Right S * Sample acidified to pH <2.	Result(ppb): <1.00
Lab No.: 7081161 Client No.: 115.1-41D	Location: Art Room 139 Far Right S * Sample acidified to pH <2.	Result(ppb): 4.00
Lab No.: 7081162 Client No.: 115.1-42	Location: Band Room Sink S * Sample acidified to pH <2.	Result(ppb): 1.70
Lab No.: 7081163 Client No.: 115.1-43	Location: Principal Office S * Sample acidified to pH <2.	Result(ppb): 4.10
Lab No.: 7081164 Client No.: 115.1-44A	Location: Main Office Main S * Sample acidified to pH <2.	Result(ppb): <1.00
Lab No.: 7081165 Client No.: 115.1-44B	Location: Main Office Bathroom S * Sample acidified to pH <2.	Result(ppb): 1.80
Lab No.: 7081166 Client No.: 115.1-45	Location: Wood Shop Steam Area S * Sample acidified to pH <2.	Result(ppb): 2.20
Lab No.: 7081167 Client No.: 115.1-46	Location: Auto Shop Steam Room S * Sample acidified to pH <2.	Result(ppb): 10.5
Lab No.: 7081168 Client No.: 115.1-47	Location: Steam Wood Shop Back Room By Door S * Sample acidified to pH <2.	Result(ppb): 6.20

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 10/19/2020
Date Analyzed: 10/22/2020
Signature: 
Analyst: Chad Shaffer

Approved By: 
Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: Stohl Environmental
3860 California Road
Orchard Park NY 14127

Client: STO708

Report Date: 10/22/2020
Report No.: 621510 - Lead Water
Project: Wellsville CSD; Wellsville Secondary School
Project No.: 2020L-115.1

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.: 7081169 **Location:** Green Lobby Drinking Fountain DO DF **Result(ppb):** <1.00
Client No.: 115.1-48A * Sample acidified to pH <2.

Lab No.: 7081170 **Location:** Green Lobby Bottle Fill DO DF **Result(ppb):** <1.00
Client No.: 115.1-48B * Sample acidified to pH <2.

Lab No.: 7081171 **Location:** Green Lobby Boys Bathroom DO S **Result(ppb):** 2.70
Client No.: 115.1-49 * Sample acidified to pH <2.

Lab No.: 7081172 **Location:** Green Lobby Girls Bathroom DO S **Result(ppb):** 3.60
Client No.: 115.1-50 * Sample acidified to pH <2.

Lab No.: 7081173 **Location:** Fitness Area Drinking Fountain DF **Result(ppb):** <1.00
Client No.: 115.1-51 * Sample acidified to pH <2.

Lab No.: 7081174 **Location:** Fitness Area Boys Bathroom S **Result(ppb):** 19.8
Client No.: 115.1-52 * Sample acidified to pH <2.

Lab No.: 7081175 **Location:** Fitness Area Girls Bathroom S **Result(ppb):** 16.2
Client No.: 115.1-53 * Sample acidified to pH <2.


Turbidity >1 NTU


Note: Sample turbidity >1.0 NTU. Does not meet Federal and NJ State Primary and Secondary Drinking Water Standards.

Lab No.: 7081176 **Location:** Boys Bathroom Across From Nurse M S **Result(ppb):** 6.20
Client No.: 115.1-54B * Sample acidified to pH <2.

Lab No.: 7081177 **Location:** Boys Bathroom Across From Nurse R S **Result(ppb):** 4.20
Client No.: 115.1-54C * Sample acidified to pH <2.

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 10/19/2020
Date Analyzed: 10/22/2020
Signature: 
Analyst: Chad Shaffer

Approved By: 
Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: Stohl Environmental
3860 California Road
Orchard Park NY 14127

Client: STO708

Report Date: 10/22/2020
Report No.: 621510 - Lead Water
Project: Wellsville CSD; Wellsville Secondary School
Project No.: 2020L-115.1

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.: 7081178 **Location:** Girls Bathroom Across From Nurse L S **Result(ppb):** <1.00
Client No.: 115.1-55A * Sample acidified to pH <2.

Lab No.: 7081179 **Location:** Girls Bathroom Across From Nurse M S **Result(ppb):** <1.00
Client No.: 115.1-55B * Sample acidified to pH <2.

Lab No.: 7081180 **Location:** Nurse Exam Room S **Result(ppb):** 1.10
Client No.: 115.1-56A * Sample acidified to pH <2.

Lab No.: 7081181 **Location:** Nurse Bathroom S **Result(ppb):** 1.70
Client No.: 115.1-56B * Sample acidified to pH <2.

Lab No.: 7081182 **Location:** Nurse Side Office S **Result(ppb):** <1.00
Client No.: 115.1-56C * Sample acidified to pH <2.

Lab No.: 7081183 **Location:** Nurse Isolation Room Exam Room S **Result(ppb):** 1.70
Client No.: 115.1-56D * Sample acidified to pH <2.


Lab No.: 7081184 **Location:** Nurse Isolation Room Bathroom S **Result(ppb):** 3.90
Client No.: 115.1-56E * Sample acidified to pH <2.


Lab No.: 7081185 **Location:** Room 104 S **Result(ppb):** <1.00
Client No.: 115.1-57 * Sample acidified to pH <2.

Lab No.: 7081186 **Location:** Room 106 Starting On Left Side; Clockwise S **Result(ppb):** <1.00
Client No.: 115.1-58A * Sample acidified to pH <2.

Lab No.: 7081187 **Location:** Room 106 S **Result(ppb):** 46.0
Client No.: 115.1-58B * Sample acidified to pH <2.

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 10/19/2020
Date Analyzed: 10/22/2020
Signature: 
Analyst: Chad Shaffer

Approved By: 
Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: Stohl Environmental
3860 California Road
Orchard Park NY 14127


Client: STO708


Report Date: 10/22/2020
Report No.: 621510 - Lead Water
Project: Wellsville CSD; Wellsville Secondary School
Project No.: 2020L-115.1

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.: 7081188 Client No.: 115.1-58C	Location: Room 106 S * Sample acidified to pH <2.	Result(ppb): 1460
Lab No.: 7081189 Client No.: 115.1-58D	Location: Room 106 S * Sample acidified to pH <2.	Result(ppb): 5.70
Lab No.: 7081190 Client No.: 115.1-59A	Location: Fountain Across From 110 DF * Sample acidified to pH <2.	Result(ppb): <1.00
Lab No.: 7081191 Client No.: 115.1-59B	Location: Bottle Filler Across From 100 DFB * Sample acidified to pH <2.	Result(ppb): <1.00
Lab No.: 7081192 Client No.: 115.1-60A	Location: Room 107 Starting At Far End S * Sample acidified to pH <2.	Result(ppb): 1.20
Lab No.: 7081193 Client No.: 115.1-60B	Location: Room 107 S * Sample acidified to pH <2.	Result(ppb): 11.8
Lab No.: 7081194 Client No.: 115.1-60C	Location: Room 107 S * Sample acidified to pH <2.	Result(ppb): <1.00
Lab No.: 7081195 Client No.: 115.1-60D	Location: Room 107 S * Sample acidified to pH <2.	Result(ppb): 10.8
Lab No.: 7081196 Client No.: 115.1-61A	Location: Drinking Fountain Across Chem Room DF * Sample acidified to pH <2.	Result(ppb): <1.00
Lab No.: 7081197 Client No.: 115.1-61B	Location: Bottle Fill Across Chem Room DFB * Sample acidified to pH <2.	Result(ppb): <1.00

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 10/19/2020
Date Analyzed: 10/22/2020
Signature: 
Analyst: Chad Shaffer

Approved By: 
Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: Stohl Environmental
3860 California Road
Orchard Park NY 14127

Report Date: 10/22/2020
Report No.: 621510 - Lead Water
Project: Wellsville CSD; Wellsville Secondary School
Project No.: 2020L-115.1

Client: STO708

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.: 7081198
Client No.: 115.1-62

Location: Chem Room S
* Sample acidified to pH <2.

Result(ppb): 43.6

Lab No.: 7081199
Client No.: 115.1-63

Location: Faculty Bath HS 114 S
* Sample acidified to pH <2.

Result(ppb): <1.00

Lab No.: 7081200
Client No.: 115.1-64A

Location: Drinking Fountain Next To 111 DF
* Sample acidified to pH <2.

Result(ppb): <1.00

Lab No.: 7081201
Client No.: 115.1-64B

Location: Bottle Fill Next To 111 DFB
* Sample acidified to pH <2.

Result(ppb): <1.00

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 10/19/2020

Date Analyzed: 10/22/2020

Signature:

Analyst: Chad Shaffer

Approved By:



Frank E. Ehrenfeld, III

Laboratory Director

CERTIFICATE OF ANALYSIS

Client: Stohl Environmental
3860 California Road
Orchard Park NY 14127

Report Date: 10/22/2020
Report No.: 621510 - Lead Water
Project: Wellsville CSD; Wellsville Secondary School
Project No.: 2020L-115.1

Client: STO708

Appendix to Analytical Report:

Customer Contact: Lab Results Final
Analysis: AAS-GF - ASTM D3559-08D

This appendix seeks to promote greater understanding of any observations, exceptions, special instructions, or circumstances that the laboratory needs to communicate to the client concerning the above samples. The information below is used to help promote your ability to make the most informed decisions for you and your customers. Please note the following points of contact for any questions you may have.

iATL Customer Service: customerservice@iatl.com
iATL Office Manager: ?wchampion@iatl.com
iATL Account Representative: Shirley Clark
Sample Login Notes: See Batch Sheet Attached
Sample Matrix: Water
Exceptions Noted: See Following Pages

General Terms, Warrants, Limits, Qualifiers:

General information about iATL capabilities and client/laboratory relationships and responsibilities are spelled out in iATL policies that are listed at www.iATL.com and in our Quality Assurance Manual per ISO 17025 standard requirements. The information therein is a representation of iATL definitions and policies for turnaround times, sample submittal, collection media, blank definitions, quantification issues and limit of detection, analytical methods and procedures, sub-contracting policies, results reporting options, fees, terms, and discounts, confidentiality, sample archival and disposal, and data interpretation.

iATL warrants the test results to be of a precision normal for the type and methodology employed for each sample submitted. iATL disclaims any other warrants, expressed or implied, including warranty of fitness for a particular purpose and warranty of merchantability. iATL accepts no legal responsibility for the purpose for which the client uses test results. Any analytical work performed must be governed by our Standard Terms and Conditions. Prices, methods and detection limits may be changed without notification. Please contact your Customer Service Representative for the most current information.

This confidential report relates only to those item(s) tested and does not represent an endorsement by NIST-NVLAP, AIHA LAP LLC, or any agency of local, state or province governments nor of any agency of the U.S. government.

This report shall not be reproduced except in full, without written approval of the laboratory.

Information Pertinent to this Report:

Analysis by AAS Graphite Furnace:

- ASTM D3559-08D

Certification:

- NYS-DOH No. 11021

- NJDEP No. 03863

Note: These methods are analytically equivalent to iATL's accredited method;

- USEPA 40CFR 141.11B

- USEPA 200.9 Pb, AAS-GF, RL <2 ppb/sample

- USEPA SW 846-7421 - Pb(AAS-GF, RL <2 ppb/sample)

Regulatory limit for lead in drinking water is 15.0 parts per billion as cited in EPA 40 CFR 141.11 National Primary Drinking Water Regulations, Subpart B: Maximum contaminant levels for inorganic chemicals.

All results are based on the samples as received at the lab. iATL assumes that appropriate sampling methods have been used and that the data upon which these results are based have been accurately supplied by the client.

Sample results are not corrected for contamination by field or analytical blanks.

PPB = Parts per billion. 1 µg/L = 1 ppb MDL = 0.24 PPB Reporting Limit (RL) = 1.0 PPB

CERTIFICATE OF ANALYSIS

Client: Stohl Environmental
3860 California Road
Orchard Park NY 14127

Report Date: 10/22/2020
Report No.: 621510 - Lead Water
Project: Wellsville CSD; Wellsville Secondary
School
Project No.: 2020L-115.1

Client: STO708

Disclaimers / Qualifiers:

There may be some samples in this project that have a "NOTE:" associated with a sample result. We use added disclaimers or qualifiers to inform the client about something that requires further explanation. Here is a complete list with highlighted disclaimers pertinent to this project. For a full explanation of these and other disclaimers, please inquire at customerservice@iatl.com.

Matrix spiking is performed on each client batch to determine if interferences could impact results. When spike recoveries fall out of acceptable range matrix interference is suspected and samples are diluted until acceptable spike recovery can be achieved. Reporting limits will increase by the same degree as the dilution required.

Note: Sample dilution required due to matrix interference.

Water Sample Turbidity greater than 1.0 NTU does not meet Federal and NJ State Primary & Secondary Drinking Water Standards.

* ASTM D3559 (D) calls for the addition of acid at the time of sampling. Unless so noted on the chain of custody by the client iATL acidifies samples to a pH of <2 at least 24 hours prior to analysis.

1.5 Laboratory Certifications

NEW YORK STATE DEPARTMENT OF HEALTH
WADSWORTH CENTER



Expires 12:01 AM April 01, 2020
Issued April 01, 2019

CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE

Issued in accordance with and pursuant to section 502 Public Health Law of New York State

MR. FRANK E. EHRENFELD III
INTERNATIONAL ASBESTOS TESTING LABS
9000 COMMERCE PARKWAY SUITE B
MOUNT LAUREL, NJ 08054

NY Lab Id No: 11021

*is hereby APPROVED as an Environmental Laboratory for the category
ENVIRONMENTAL ANALYSES POTABLE WATER
All approved subcategories and/or analytes are listed below:*

Metals I

Lead, Total ASTM D3559-90, 96, 03 & 08 (D)

Miscellaneous

Asbestos EPA 100.1
 EPA 100.2

NEW YORK STATE Department
of Health

Serial No.: 59524

Property of the New York State Department of Health. Certificates are valid only at the address shown, must be conspicuously posted, and are printed on secure paper. Continued accreditation depends on successful ongoing participation in the Program. Consumers are urged to call (518) 485-5570 to verify the laboratory's accreditation status.

1.6 Chains of Custody



3860 California Road, Orchard Park, New York 14127
PHONE (716) 312-0070 FAX (716) 312-8092
WWW.STOHLNENVIRONMENTAL.COM

Chain of Custody Document

Submitted to: (Lab Name) IATL

STOHL Job # 2020L-115.1

Client: Wellsville CSD

Contact: Emily Peavey

Building: Wellsville Secondary School

Location: 126 West State St. Wellsville, NY 14895

LEAD

Water by AAS-GF: ASTM D3559-03D, US EPA 200.9 X

Turnaround

20 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
115.1-1A	Drinking fountain 3 floor MS	DF	1:50	7081067		
115.1-1B	Bottle filler 3 floor ms	DFB	1:51	7081068		
115.1-2	Faculty across 306 3 floor ms	S	1:52	7081069		
115.1-3A	Boys bathroom 3 floor MS L	S	1:53	7081070		
115.1-4A	Girls bathroom 3 floor MS L	S	1:54	7081071		
115.1-4B	Girls bathroom 3 floor MS m	S	1:55	7081072		
115.1-4C	Girls bathroom 3 floor MS r	S	1:56	7081073		
115.1-5	Faculty by elevator 3 floor ms	S	1:57	7081074		
115.1-6A	Drinking fountain 3 floor HS	DF	1:58	7081075		
115.1-6B	Bottle filler 3 floor hs	DFB	1:59	7081076		
115.1-7A	Boys bathroom 3 floor hs L	S	2:00	7081077		
115.1-7B	Boys bathroom 3 floor hs M	S	2:01	7081078		
115.1-7C	Boys bathroom 3 floor hs R	S	2:02	7081079		
115.1-8A	Girls bathroom 3 floor hs L	S	2:03	7081080		
115.1-8B	Girls bathroom 3 floor hs M	S	2:04	7081081		
115.1-8C	Girls bathroom 3 floor hs R	S	2:05	7081082		
115.1-9	Faculty bathroom 3 floor hs	S	2:06	7081083		
115.1-10A	Drinking fountain 2nd hs	DF	2:07	7081084		

Notes:

Please e-mail lab results to labs@stohlenv.com

☒ If checked, also e-mail results to:

Ehenderson@StohlEnv.com

Sampled By: Christine Schultz Print Name

Stohl Env: Christine Schultz

Date: 10/14/2020

Relinquished By: E. Henderson Jr. Print Name

Stohl Env: Eric Henderson Jr.

Date: 10/15/2020

Received (Name / Lab): _____

Date: _____

Time: RECEIVED

Sample Login (Name / Lab): _____

Date: _____

Time: _____

Analysis (Name / Lab): 10/22/20

Date: _____

Time: OCT 19 2020

QA/QC Review (Name / Lab): 10/26/20

Date: _____

Time: _____

Archived / Released: _____

QA/QC InterLAB Use: _____

Date: _____

Time: _____



3860 California Road, Orchard Park, New York 14127
PHONE (716) 312-0070 FAX (716) 312-8092
WWW.STOHLENVIRONMENTAL.COM

Chain of Custody Document

Submitted to: (Lab Name) iATL

STOHL Job # 2020L-115.1

Client: Wellsville CSD

Contact: Emily Peavey

Building: Wellsville Secondary School

Location: 126 West State St. Wellsville, NY 14895

LEAD

Water by AAS-GF: ASTM D3559-03D, US EPA 200.9 X

Turnaround

20 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
115.1-10B	Bottle filler 2nd hs	DFB	2:08	7081085		
115.1-11A	Boys bathroom 2nd hs l	S	2:09	7081096		
115.1-11B	Boys bathroom 2nd hs m	S	2:10	7081087		
115.1-12A	Girls bathroom 2nd hs l	S	2:11	7081088		
115.1-12B	Girls bathroom 2nd hsm	S	2:12	7081090		
115.1-13A	Drink fountain 2nd hs 210	DF	2:13	7081090		
115.1-13B	Bottle fill 2nd hs 210	DFB	2:14	7081091		
115.1-14	Faculty bathroom 2nd ms	S	2:15	7081091		
115.1-15A	Boys hs Locker room L	S	2:16	7081093		
115.1-15B	Boys hs Locker room M	S	2:17	7081094		
115.1-16	Boys hs gym office	S	2:18	7081095		
115.1-17A	Hs gym drinking fountain	DF	2:19	7081096		
115.1-17B	Hs gym bottle fill	DFB	2:20	7081097		
115.1-18	Girls hs gym office	S	2:21	7081098		
115.1-19A	Girls hs locker room L	S	2:22	7081099		
115.1-19B	Girls hs locker room M	S	2:23	7081100		
115.1-19C	Girls hs locker room R	S	2:24	7081101		
115.1-20	Faculty room 2nd ms	S	2:25	7081102		

Notes:

Please e-mail lab results to labs@stohlenv.com

Sampled By: Christine Schultz Print Name Stohl Env: Christine Schultz Date: 10/14/2020

Relinquished By: E. Henderson Jr. Print Name Stohl Env: Eric Henderson Jr. Date: 10/15/2020

Received (Name / Lab): _____ Date: _____ Time: _____

Sample Login (Name / Lab): _____ Date: _____ Time: _____

Analysis (Name / Lab): _____ Date: _____ Time: _____

QA/QC Review (Name / Lab): _____ Date: _____ Time: _____

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____



3860 California Road, Orchard Park, New York 14127
PHONE (716) 312-0070 FAX (716) 312-8092
WWW.STOHLENVIRONMENTAL.COM

Chain of Custody Document

Submitted to: (Lab Name) iATL

STOHL Job # 2020L-115.1

Client: Wellsville CSD

Contact: Emily Peavey

Building: Wellsville Secondary School

Location: 126 West State St. Wellsville, NY 14895

LEAD

Water by AAS-GF: ASTM D3559-03D, US EPA 200.9 X

Turnaround

20 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
115.1-21	Faculty bathroom 2nd ms	S	2:26	70811-03		
115.1-22A	Girls bathroom 2nd ms L	S	2:27	70811-04		
115.1-22B	Girls bathroom 2nd ms M	S	2:28	70811-05		
115.1-22C	Girls bathroom 2nd ms R	S	2:29	70811-06		
115.1-23A	Boys bathroom 2nd ms L	S	2:30	70811-07		
115.1-23B	Boys bathroom 2nd ms M	S	2:31	70811-08		
115.1-24A	2nd ms water fountain	DF	2:32	70811-09		
115.1-24B	2nd ms bottle fill	DFB	2:33	70811-10		
115.1-24C	2nd floor shorter fountain	DF	2:34	70811-11		
115.1-25	Faculty room by water ftn	S	2:35	70811-12		
115.1-26A	Drinking fountain across from kitchen	S	2:36	70811-13		
115.1-26B	Bottle fill across from kitchen	S	2:37	70811-14		
115.1-27	Staff locker room	S	2:38	70811-15		
115.1-28A	Girls bathroom across kitchen L	S	2:39	70811-16		
115.1-28B	Girls bathroom across kitchen M	S	2:40	70811-17		
115.1-28C	Girls bathroom across kitchen R	S	2:41	70811-18		
115.1-29A	Boys bathroom across kitchen L	S	2:42	70811-19		
115.1-29B	Boys bathroom across kitchen M	S	2:43	70811-20		

Notes:

Please e-mail lab results to labs@stohlenv.com

Sampled By: Christine Schultz Print Name Stohl Env: Christine Schultz Date: 10/14/2020

Relinquished By: E. Henderson Jr. Print Name Stohl Env: Eric Henderson Jr. Date: 10/15/2020

Received (Name / Lab): _____ Date: _____ Time: _____

Sample Login (Name / Lab): _____ Date: _____ Time: _____

Analysis (Name / Lab): _____ Date: _____ Time: _____

QA/QC Review (Name / Lab): _____ Date: _____ Time: _____

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____



3860 California Road, Orchard Park, New York 14127
PHONE (716) 312-0070 FAX (716) 312-8092
WWW.STOHLENVIRONMENTAL.COM

Chain of Custody Document

Submitted to: (Lab Name) iATL

STOHL Job # 2020L-115.1

Client: Wellsville CSD

Contact: Emily Peavey

Building: Wellsville Secondary School

Location: 126 West State St. Wellsville, NY 14895

LEAD

Water by AAS-GF: ASTM D3559-03D, US EPA 200.9 X

Turnaround

20 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
115.1-29C	Boys bathroom across kitchen R	S	2:44	7081121		
115.1-30A	girls locker room sink L	S	2:45	7081122		
115.1-30B	girls locker room sink R	S	2:46	7081123+		
115.1-30C	Girls locker room ms drinking	DF	2:47	7081124		
115.1-31B	Boys ms locker room sink L	S	2:48	7081125		
115.1-31C	Boys ms locker room drinking ftn	DF	2:49	7081126		
115.1-32	Boys PE Office ms	S	2:50	7081127		
115.1-33A	Kitchen ice machine	IM	2:51	7081128		
115.1-33B	Kitchen Dish hose	S	2:52	7081129		
115.1-33C	Kitchen Dish room hand wash front	S	2:53	7081130		
115.1-33D	Kitchen ice room hand wash front	S	2:54	7081131		
115.1-33E	Kitchen main	S	2:55	7081132		
115.1-33F	Kitchen triple L	S	2:56	7081133		
115.1-33G	Kitchen triple R	S	2:57	7081134+		
115.1-33H	Kitchen hand wash next to triple	S	2:58	7081135		
115.1-33I	Kitchen kettle rice cooker	S	2:59	7081136		
115.1-33J	Kitchen back Dish room sink hose	S	3:00	7081137		
115.1-33K	Kitchen back Dish room hand wash	S	3:01	7081138		

Notes:

Please e-mail lab results to labs@stohlenvironmental.com

Sampled By: Christine Schultz Print Name Stohl Env: Christine Schultz Date: 10/14/2020

Relinquished By: Eric Henderson Jr. Print Name Stohl Env: Eric Henderson Jr. Date: 10/15/2020

Received (Name / Lab): _____ Date: _____ Time: _____

Sample Login (Name / Lab): _____ Date: _____ Time: _____

Analysis (Name / Lab): _____ Date: _____ Time: _____

QA/QC Review (Name / Lab): _____ Date: _____ Time: _____

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____



3860 California Road, Orchard Park, New York 14127
 PHONE (716) 312-0070 FAX (716) 312-8092
 WWW.STOHLENVIRONMENTAL.COM

Chain of Custody Document

Submitted to: (Lab Name) iATL

STOHL Job # 2020L-115.1

Client: Wellsville CSD

Contact: Emily Peavey

Building: Wellsville Secondary School

Location: 126 West State St. Wellsville, NY 14895

LEAD

Water by AAS-GF: ASTM D3559-03D, US EPA 200.9 X

Turnaround

20 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
115.1-33L	Kitchen wall mount faucet	S	3:02	70811039		
115.1-33M	Kitchen double sink	S	3:03	70811040		
115.1-34A	Cafe drinking fountain right	DF	3:04	70811041		
115.1-34B	CAFE BOTTLE FILL right	DFB	3:05	70811042		
115.1-35A	Cafe drinking fountain left	DF	3:06	70811043		
115.1-35B	Cafe bottle fill left	DFB	3:07	70811044		
115.1-36B	girls bathroom ms 1st M	S	3:08	70811045		
115.1-37A	Boys bathroom ms 1st L	S	3:09	70811046		
115.1-37B	Boys bathroom ms M	S	3:10	70811047		
115.1-37C	Boys bathroom ms R	S	3:11	70811048		
115.1-38	Ms 1st faculty bathroom	S	3:12	70811049		
115.1-39A	Ms 1st drinking ftn next to faculty	S	3:13	70811050		
115.1-39B	Ms 1st bottle fill next to faculty	S	3:14	70811051		
115.1-40A	Art room 142 clockwise around room	S	3:15	70811052		
115.1-40B	Art room 142	S	3:16	70811053		
115.1-40C	Art room 142	S	3:17	70811054		
115.1-40D	Art room 142	S	3:18	70811055		
115.1-40E	Art room 142	S	3:19	70811056		

Notes:

Please e-mail lab results to labs@stohlenv.com

Sampled By: Christine Schultz Print Name Stohl Env: Christine Schultz Date: 10/14/2020

Relinquished By: E. Henderson Jr. Print Name Stohl Env: Eric Henderson Jr. Date: 10/15/2020

Received (Name / Lab): _____ Date: _____ Time: _____

Sample Login (Name / Lab): _____ Date: _____ Time: _____

Analysis (Name / Lab): _____ Date: _____ Time: _____

QA/QC Review (Name/Lab): _____ Date: _____ Time: _____

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____



3860 California Road, Orchard Park, New York 14127
 PHONE (716) 312-0070 FAX (716) 312-8092
 WWW.STOHLENVIRONMENTAL.COM

Chain of Custody Document

Submitted to: (Lab Name) iATL

STOHL Job # 2020L-115.1

Client: Wellsville CSD

Contact: Emily Peavey

Building: Wellsville Secondary School

Location: 126 West State St. Wellsville, NY 14895

LEAD

Water by AAS-GF: ASTM D3559-03D, US EPA 200.9 X

Turnaround

20 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
115.1-40F	Art room 142	S	3:20	70811653		
115.1-41A	Art room 139 far left	S	3:21	70811659		
115.1-41B	Art room 139 Middle left	S	3:22	70811659		
115.1-41C	Art room 139 Middle right	S	3:23	70811660		
115.1-41D	Art room 139 far right	S	3:24	70811661		
115.1-42	Band room sink	S	3:25	70811662		
115.1-43	Principal office	S	3:26	70811662		
115.1-44A	Main Office main	S	3:27	70811663		
115.1-44B	Main Office bathroom	S	3:28	70811663		
115.1-45	Wood shop STEAM area	S	3:29	70811664		
115.1-46	Auto shop STEAM room	S	3:30	70811664		
115.1-47	STEAM wood shop back room by door	S	3:31	70811664		
115.1-48A	Green lobby drinking fountain DO	DF	3:32	70811664		
115.1-48B	Green lobby bottle fill DO	DFB	3:33	70811664		
115.1-49	Green lobby boys bathroom DO	S	3:34	70811670		
115.1-50	Green lobby girls bathroom DO	S	3:35	70811670		
115.1-51	Fitness area drinking fountain	DF	3:36	70811673		
115.1-52	Fitness area boys bathroom	S	3:37	70811674		

Notes:

Please e-mail lab results to labs@stohlenvironmental.com

Sampled By: Christine Schultz Print Name Christine Schultz Date: 10/14/2020

Relinquished By: Eric Henderson Jr. Print Name Eric Henderson Jr. Date: 10/15/2020

Received (Name / Lab): _____ Date: _____ Time: _____

Sample Login (Name / Lab): _____ Date: _____ Time: _____

Analysis (Name / Lab): _____ Date: _____ Time: _____

QA/QC Review (Name / Lab): _____ Date: _____ Time: _____

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____



3860 California Road, Orchard Park, New York 14127
 PHONE (716) 312-0070 FAX (716) 312-8092
 WWW.STOHLENVIRONMENTAL.COM

Chain of Custody Document

Submitted to: (Lab Name) iATL

STOHL Job # 2020L-115.1

Client: Wellsville CSD

Contact: Emily Peavey

Building: Wellsville Secondary School

Location: 126 West State St. Wellsville, NY 14895

LEAD

Water by AAS-GF: ASTM D3559-03D, US EPA 200.9 X

Turnaround

20 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
115.1-53	Fitness area girls bathroom	S	3:38	7081175		
115.1-54B	Boys bathroom across from Nurse M	S	3:39	7081176		
115.1-54C	Boys bathroom across from Nurse R	S	3:40	7081177		
115.1-55A	Girls bathroom across from Nurse L	S	3:41	7081178		
115.1-55B	Girls bathroom across from Nurse M	S	3:42	7081179		
115.1-56A	Nurse exam room	S	3:43	7081180		
115.1-56B	Nurse bathroom	S	3:44	7081181		
115.1-56C	Nurse side office	S	3:45	7081182		
115.1-56D	Nurse isolation room exam room	S	3:46	7081183		
115.1-56E	Nurse isolation room bathroom	S	3:47	7081184		
115.1-57	Room 104	S	3:48	7081185		
115.1-58A	Room 106 starting on left side, clockwise	S	3:49	7081186		
115.1-58B	Room 106	S	3:50	7081187		
115.1-58C	Room 106	S	3:51	7081188		
115.1-58D	Room 106	S	3:52	7081189		
115.1-59A	Fountain across from 110	DF	3:53	7081190		
115.1-59B	Bottle filler across from 100	DFB	3:54	7081191		
115.1-60A	Room 107 starting at far end	S	3:55	7081192		

Notes:

Please e-mail lab results to labs@stohlenv.com

Sampled By: Christine Schultz Print Name Stohl Env: Christine Schultz Date: 10/14/2020

Relinquished By: Eric Henderson Jr. Print Name Stohl Env: Eric Henderson Jr. Date: 10/15/2020

Received (Name / Lab): _____ Date: _____ Time: _____

Sample Login (Name / Lab): _____ Date: _____ Time: _____

Analysis (Name / Lab): _____ Date: _____ Time: _____

QA/QC Review (Name / Lab): _____ Date: _____ Time: _____

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____



STOHL Job # 2020L-115.1

Location: 126 West State St. Wellsville, NY 14895

20 Days

Page 8 of 8